



**Notes:**

- All power supplies are to be HARDWIRED
- Service Panel: Use HIGH MAGNETIC C.B. (GE THQL11XXHM, XX = Amps) or equivalent
- Use TWO WIRE COLORS (e.g. black and white) to differentiate polarities
- Installation according to NEC article 424.90 through 99